


- NOTES: 1) THIS DETAIL APPLIES ONLY TO WALL BARS INTERRUPTED BY PIER. ABOVE PIER USE DETAIL 4/S5.01.  
2) BUSH PIER SURFACE TO 1/4" AMPLITUDE.  
3) APPLY REZI-WELD BONDING AGENT WHERE NEW CONCRETE IS POURED AGAINST EXISTING CONCRETE.  
4) LAP SPLICE DOWEL BARS AND HORIZONTAL WALL BARS.

FOR BALANCE OF INFO, SEE 



#6 HORIZ @ 12" EF, TYP  
#5 VERT @ 12" EF, TYP

#6 ADH DOWELS @ 12". SET WITH HILTI HIT-HY 200 CONFORMING TO ICC-ES REPORT ESR-3187. EMBED 14".

#5 ADH DOWELS @ 12". SET WITH HILTI HIT-HY 200 CONFORMING TO ICC-ES REPORT ESR-3187. EMBED 14".

(E) CONCRETE PIER

#5 ADH DOWELS @ 12". SET W/ HILTI HIT-HY 200 CONFORMING TO ICC-ES REPORT ESR-3187. EMBED 14"

CONCRETE WALL CONNECTION  
AT G-3 CORNER PIER

1"=1'-0"

