


Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY	USCS	AASHTO	PL	LL
		99.6		0.4				

SIEVE inches size	PERCENT FINER	
	○	
GRAIN SIZE		
D ₆₀	0.251	
D ₃₀	0.192	
D ₁₀	0.155	
COEFFICIENTS		
C _c	0.95	
C _u	1.62	

SIEVE number size	PERCENT FINER	
	○	
#10	100.0	
#30	99.9	
#40	99.5	
#50	77.7	
#100	7.6	
#200	0.4	

SOIL DESCRIPTION
 ○ Brown Poorly Graded SAND

REMARKS:
 ○

○ Source: Grab

COOPER TESTING LABORATORY	Client: Geoplex
	Project: Le Residence San Francisco
	Project No.: 347-029