



SMITH-EMERY SAN FRANCISCO
 1940 Oakdale Ave, San Francisco, CA 94124
 (415) 642-7326
 LEA #56

DSA File # N/A
 DSA Appl. # N/A
 OSHPD # N/A
 Permit # N/A

DAILY SPECIAL INSPECTION REPORT

Project Name: 240 Highland Avenue. Date: 12/18/2020
 Project Address: 240 Highland Avenue. SESF Job # 72639-1
 Inspection Location: Grad beams Grid line: A-C@3-4.
 Inspection(s) Performed: Concrete - Placement
 Document(s) Reviewed: S2.

Inspection Report:


Arrived on job site as requested for the purpose of concrete sampling, observation and monitored, temp, verified trip truck tickets for compliance to approved mixed design addition of water and verified Concrete, Vibration was performed during pour concrete, with Mix # 6367AP (3000psi), Shamrock company, Via pump, -Total was 18 cubic yards.(+/-), i got one set of (Five) (4x8)" cylinders sample from the middle portion of truck discharged as follow location, Grad beams Grid line: A-C@3-4.

Work WAS WAS NOT Inspected in Accordance with the Requirements of DSA OSHPD JURISDICTION Approved Documents N/A
 Work Inspected MET DID NOT MEET The Requirements of the DSA OSHPD JURISDICTION Approved Documents N/A
 Material WAS WAS NOT Sampled and Tested in Accordance with the Requirements of DSA OSHPD JURISDICTION Approved Documents N/A
 Material Tested MET DID NOT MEET The Requirements of the DSA OSHPD JURISDICTION Approved Documents N/A

Work Not In Compliance: _____ Notified (Required) _____

Attachments: _____ Name: Fahim Karimi

CC: DSA Regional Office
 Project Architect
 Structural Engineer
 Project Inspector
 School District

Signature: 
 Certification # ACI #01400990, ICC # 8881845
 Emp. ID: 9134 Page 1 of 1